



Consulting engineers in:
– Acoustics
– Building physics

Kees Rijk BV
Watertorenweg 24
6571 CB Berg en Dal
The Netherlands
info@keesrijk.nl

Fire resistance REI 240 Legioblock



Kees Rijk BV confirms that Legioblock walls with a separating function have a fire resistance of 240 minutes, in accordance with the standards NEN 6069:2011 and EN 13501-2:2016.

This summary is based on the report 171404a “Legioblock concrete retaining walls; Fire resistance study“. In the report, the application area and the limiting conditions are described.

Ir. C.A.E. (Kees) Rijk
17 April 2017

Contact: Jansen Legioblock BV, +31 (0)88 8778778, sales@legioblock.com